

**ADDENDUM #3**  
**BID #1718-24, Parking Lot 5 Expansion at Cypress College**

This Addendum forms a part of the Contract Documents and modifies the original Contract Documents. Acknowledge receipt of this Addendum in space provided on the Bid Proposal Form. Failure to acknowledge may subject Bidder to disqualification.

**I. REQUEST FOR INFORMATION:**

1. The sizing of the 2'X3'X3' Inside dimensions of the pull-boxes called out. In most cases it is 3- 1" conduits in these Pull-boxes. There are other traffic rated pull-boxes (smaller in size) that may be used in place of these large boxes." Will smaller pull-boxes be acceptable and if so, is there a specified manufacturer that would be required?  
**A. For pullboxes not exceeding three (3) 1" conduits, 14 1/2" x 25" would be acceptable. We suggest H20 pullboxes with traffic covers as manufactured by Eisel or equal.**
  
2. During our job walk it was mentioned that the district will supply all of their light fixtures (Type SL1, SL2), so we will only be including the installation cost of the light fixtures in our proposal, is this correct?  
**A. We've already ordered the light poles and light fixtures for the parking lot. However, The contractor will need to provide the light poles and fixtures for the walkways.**
  
3. During our job walk it was mentioned that the district will handle the erosion/sedimentation control around the perimeter of the construction area, and the temporary fencing was to remain, is this correct?  
**A. We have the contract on the temporary fences and the erosion control. However the contractor will need to maintain the integrity of the fences for the project duration and cover the cost of any changes or modification needed on the existing set up.**

**END OF ADDENDUM #3**