

# GENERAL NOTES:

1. VERIFY EXACT LOCATION AND ELEVATION OF ALL OUTLETS IN FIELD PRIOR TO ROUGHING-IN. REFER TO ARCHITECTURAL AND ID PLANS AND ELEVATIONS.
2. COORDINATE LOCATION AND MOUNTING OF ALL OUTLETS IN CASEWORK WITH THE MILLWORK CONTRACTOR AND FOOD SERVICE CONTRACTOR.
3. CONTRACTOR TO COORDINATE WITH OWNER/OPERATOR AND MANUFACTURER FOR POWER, DATA AND PHONE REQUIREMENTS AS WELL AS EQUIPMENT OUT SHEETS AND PRODUCT SPECIFICATIONS. REFER TO ARCHITECTURAL ELEVATIONS.
4. ALL EXPOSED TO VIEW CONVENIENCE OUTLETS SHALL BE GANGED IN A COMMON PLATE AND SHALL BE FINISHED TO MATCH COLOR OF ADJACENT FINISH.
5. CONTRACTOR TO ENSURE THAT ALL POWER, DATA AND ELECTRICAL WIRING IS FULLY CONCEALED AND YET FULLY ACCESSIBLE WITHIN MILLWORK.
6. ROUTE ALL WIRING INSIDE THE MILLWORK IN METALLIC FLEXIBLE CONDUIT.
7. CIRCUITING INFORMATION AND CIRCUIT NUMBERS WERE DEVELOPED FROM THE EXISTING ELECTRICAL PLANS PROVIDED BY THE OWNER, AND SHOWN FOR GENERAL INFORMATION. CONTRACTOR SHALL FIELD VERIFY EXISTING CONDITIONS, AND SHALL MAKE REQUIRED ADJUSTMENTS. INDICATE ON THE 'AS-BUILT' DRAWINGS.
8. ALL NEW OUTLETS WITHIN THE PROJECT AREA, SHALL BE GFCI PROTECTED.
9. CONTRACTOR SHALL RE-CONNECT ALL RELOCATED EQUIPMENT TO SAME SOURCE OF POWER. UTILIZE SAME SIZE OF BRANCH CIRCUIT WIRING. PROVIDE OUTLETS TO MATCH THE EQUIPMENT. COORDINATE IN FIELD.

# SPECIFIC NOTES:


1. PROVIDE NEW LOAD CENTER, VERIFY EXACT LOCATION IN FIELD. MODIFY CASEWORK TO ACCOMMODATE THE NEW LOAD CENTER. PROVIDE MIN. 36" CLEARANCE IN FRONT OF PANEL. SQ. D #Q0312L125G/Q0C16US, OR EQUAL.
2. UTILIZE EXISTING CONDUITS. INTERCEPT EXISTING CONDUIT ABOVE PANEL 'KB' AND RE-ROUTE TO PANEL 'KC'. PULL IN NEW WIRES TO PANEL AS REQUIRED FOR NEW EQUIPMENT, TERMINATE AT THE NEW OUTLETS. SUBJECT TO FIELD COORDINATION. PROVIDE NEW 15A-2POLE CIRCUIT BREAKERS. SEE PANEL SCHEDULE.
3. CONTRACTOR SHALL RE-WORK EXISTING AND NEW BRANCH CIRCUITING TO ACCOMMODATE NEW EQUIPMENT. SEE SPECIFIC NOTES 7 AND 8. SUBJECT TO FIELD COORDINATION.
4. POWER TO THE EQUIPMENT UNDER THE HOOD SHALL BE SHUT DOWN IN THE EVENT OF FIRE. INTERLOCK WITH HOOD FIRE SUPPRESSION SYSTEM. PROVIDE ALL REQUIRED CONTRACTORS, WIRING, INTERFACE EQUIPMENT. COORDINATE IN FIELD.
5. NOT USED.
6. STUB OUT 3/4" C WITH PULL CORD INTO ACCESSIBLE CEILING SPACE.
7. CONTRACTOR SHALL PULL IN NEW ADDITIONAL BRANCH CIRCUIT WIRES IN EXISTING CONDUIT, 2#10,1#10C. CONNECT TO EQUIPMENT #6.
8. PROVIDE NEW 30A-1P BRANCH CIRCUIT BREAKER IN SPACE #42. SUBJECT TO FIELD COORDINATION.
9. CONTRACTOR SHALL RE-ROUTE CONDUITS TO NEW LOCATION OF THE EXISTING PIZZA OVEN. EXTEND BRANCH CIRCUIT, AND RE-CONNECT AS REQUIRED. PROVIDE NEW DISCONNECT SWITCH AND CONTACTOR AS REQUIRED. COORDINATE ENTIRE INSTALLATION IN FIELD.

Measurements on this plan have been secured by KEAGGY from available information, but KEAGGY assumes no responsibility for the accuracy of such measurements. These plans and the design contained herein are the property of KEAGGY and may not be reproduced or used by anyone, other than the client, without first securing the written permission of KEAGGY.

**PROJECT COORDINATION FOR FOOD SERVICE DESIGN:**  
**DAVE KEAGGY & ASSOC.**  
 3806 NORTH 30TH STREET  
 PHOENIX, ARIZONA 85016  
 TEL: 602.273.1900 FAX: 602.273.9937  
 DAVE KEAGGY

**ROBERT GINSBERG & ASSOC.**  
 9018 LINDBLADE STREET  
 CULVER CITY, CA 90232  
 TEL: 310.815.2000 FAX: 310.841.6228  
 BOB GINSBERG

**KENNETH L. BUTTS, AIA**  
 124 STAGECOACH ROAD  
 BELL CANYON, CA 91307  
 TEL: 818.999.4272 FAX: 818.999.4321  
 KEN BUTTS



**CONSULTING ENGINEERS**

**SILVER, ROTH & ASSOCIATES INC.**  
 CONSULTING ELECTRICAL ENGINEERS  
 811 SOUTH TARBAN AVENUE  
 LOS ANGELES, CALIFORNIA 90005-1019  
 TEL: (213) 683-7000 FAX: (213) 683-5874  
 EMAIL: rrs@silverroth.com

**FOOD SERVICE OPERATOR:**

**sodexo**  
**SODEXO CAMPUS SERVICES**  
 FULLERTON COLLEGE  
 CAMPUS COMMONS BLDG. #200  
 321 EAST CHAPMAN AVE.  
 FULLERTON, CALIFORNIA 92832  
 ATTN: DONNA PROVOST GENERAL MGR.  
 TEL: 714.732.5784 CEL: 714.371.3207  
 ATTN: RICK NARGI DISTRICT MGR.  
 TEL: 714.719.2731 FAX: 714.744.7643

**CLIENT:**

**FULLERTON COLLEGE**  
 FULLERTON COLLEGE  
 NORTH ORANGE COUNTY CCD  
 321 EAST CHAPMAN AVE.  
 FULLERTON, CALIFORNIA 92832  
 ATTN: ADAM M. O'CONNOR  
 DIRECTOR, BUDGET & FINANCE  
 TEL: 714.992.7004 FAX: 714.992.9911

**PROJECT:**  
**SERVRY RETROFIT & COSMETIC FINISHES**

**REVISIONS:**

NO.	DATE	DESCRIPTION
1		
2		
3		
4		
5		

**SHEET TITLE:**  
**POWER PLAN**

**DATE:** FEB 27 2013  
**SS:** 02  
**112545**

**03/15/12**

**SCALE:**

**AS SHOWN**

**DRAWN BY:**  
**DKC / RBG**

**JOB NUMBER:**  
**080111**

**SHEET NO:**

**E2.1**