

- FOOD SERVICE GENERAL EQUIPMENT NOTES.**
- General Contractor shall provide a smooth, non absorbent, easily cleanable surface, light in color for walls and ceilings for all food service areas and rest rooms. Surfaces shall have a 70 % reflective value.
 - General Contractor shall provide a smooth cove surface at the juncture of wall and floor in all food service, dressing and rest room areas. Cove to be six (6) inches high and have a 3/8" radius cove. Use ceramic tile base feathered at floor juncture with concrete floor. Architect and/or Interior Designer to provide paint and tile samples for health department review and approval prior to installation.
 - General Contractor shall provide a smooth non absorbent washable wall behind and adjacent to all plumbing fixtures in rest rooms. If a urinal is to be provided, it will be used 24-inches wide x 48-inches high with urinal centered. Splash guards must be provided. See architectural/interior design drawings, provided by others, for details.
 - General Contractor to consult with Owner if any special water treatment are to be used in this project. See architectural/mechanical engineered drawings, by others, for details, sizing information and location for water softener, water filtering system and hot water heater. Hot water heater to be of adequate capacity but not less than 35 gallons. Furnish a continuous supply of 120 degree hot water to all lavatories, dish and utensil washing fixtures etc. Hot water heater to be mounted on six (6) inch high legs and clear of walls by a minimum of six (6) inches or per local code requirements.
 - General Contractor to verify with Architect/mechanical engineer for grease trap/interceptor requirements and location. HEALTH DEPARTMENT DOES NOT ALLOW SUCH DEVICES TO BE LOCATED IN ANY FOOD SERVICE AREA, INCLUDING DRY STORAGE AND DRESSING ROOMS.
 - General Contractor to provide self closure devices of all doors.
 - General Contractor to provide mechanical air fans for air exchanges as required by local codes in dressing rooms, rest rooms and dry storage rooms. Fans to be activated via light switch. See mechanical drawings, provided by others, for details and specifications.
 - General Contractor will see that any operable windows shall be screened with permanently affixed screens. All food service pass through openings to the outside shall be limited to a maximum of 216 square inches. The minimum distance between openings may not be less than eighteen (18) inches. The counter surface of the pass through window must be smooth, free of channels and crevices and be easily cleanable.
 - General Contractor shall provide in every room and area in which food is prepared, processed or packaged, or in which utensils are cleaned, sufficient natural or artificial lighting shall be provided to produce the following light intensity while the area is in use:
 - at least 10-foot candles at a distance of 30 inches above the floor in walk-in refrigeration units and dry food storage areas;
 - at least 20-foot candles where food is provided for consumer self-service; where fresh produce or pre-packaged foods are sold or offered for consumption; inside equipment such as reach-in and under-counter refrigerators; hand washing areas; warewashing areas; equipment and utensil storage areas; and in toilet rooms;
 - at least 50-foot candles at surfaces where food employee is working with food or with utensils, equipment such as toasters, slicers, grinders, or saws where employee safety is a factor; and in other rooms during periods of cleaning.
 - General Contractor, Owner and/or Architect shall notify local health department at least one (1) week in advance for preliminary and final health inspections. NO FOOD can be present on the premises until after final health department inspection and issuance of a health permit. FAILURE TO COMPLY WILL RESULT IN CANCELLATION OF HEALTH INSPECTION UNTIL ALL FOOD PRODUCTS ARE REMOVED FROM THE PREMISES.

Food Service equipment indicated on these drawings shall be manufactured and fabricated to meet the following:


N.S.F.	National Sanitation Foundation.
U.L.	Underwriters Laboratory.
A.G.A.	American Gas Association.
A.S.M.E.	American Society of Mechanical Engineers.
N.F.P.A.	National Fire Protection Association.

Measurements on this plan have been secured by KEAGGY from available information. KEAGGY assumes no responsibility for the accuracy of such measurements. These plans and the design contained herein are the property of KEAGGY and may not be reproduced or used by anyone, other than the party, without first securing the written permission of KEAGGY.

PROJECT COORDINATION FOR FOOD SERVICE DESIGN:
DAVE KEAGGY & ASSOC.
 3806 NORTH 30TH STREET
 PHOENIX, ARIZONA 85016
 TEL: 602.273.1900 FAX: 602.273.9937
 DAVE KEAGGY

ROBERT GINSBERG & ASSOC.
 9018 LINDBLADE STREET
 CULVER CITY, CA 90232
 TEL: 310.615.2000 FAX: 310.641.6228
 BOB GINSBERG

KENNETH L. BUTTS, AIA
 124 STAGECOACH ROAD
 BELL CANYON, CA 91307
 TEL: 818.999.4272 FAX: 818.999.4321
 KEN BUTTS




SILVER ROTH & ASSOC.
 5111 SOUTH FAIRFAX AVENUE
 LOS ANGELES, CA 91307
 TEL: 323.933.3700 FAX: 323.933.3874
 FELIX ROTH ELECT. ENGINEER

COMEAU ENGINEERS, INC.
 3128 ATWATER AVENUE
 LOS ANGELES, CA 90039
 TEL: 323.665.5946 FAX: 323.665.1478
 BILL COMEAU MECH. ENGINEER

FOOD SERVICE OPERATOR:

sodexo
SODEXO CAMPUS SERVICES
 FULLERTON COLLEGE
 CAMPUS COMMONS BLDG. #200
 321 EAST CHAPMAN AVE.
 FULLERTON, CALIFORNIA 92832
 ATTN: DONNA PROVOST GENERAL MGR.
 TEL: 714.732.5784 CEL: 714.371.3207
 ATTN: RICK NARGI DISTRICT MGR.
 TEL: 714.719.2731 FAX: 714.744.7643

CLIENT:



FULLERTON COLLEGE
 NORTH ORANGE COUNTY CCD
 321 EAST CHAPMAN AVE.
 FULLERTON, CALIFORNIA 92832

ATTN: ADAM M. O'CONNOR
 DIRECTOR, BUDGET & FINANCE
 TEL: 714.992.7004 FAX: 714.992.9911

PROJECT:

SERVERY RETROFIT & COSMETIC FINISHES

REVISIONS:

NO.	DATE	DESCRIPTION
1		
2		
3		
4		
5		

SHEET TITLE:
FOOD SERVICE EQUIPMENT & FLOOR PLAN
 04 12545
 DATE: FEB 27 2013
 10/03/11

SCALE:
AS SHOWN
DRAWN BY:
DCK / RBG
JOB NUMBER:
080111

SHEET NO:

FS-1.0